

Facility Summary in WIBAUX County in the City of WIBAUX

Location: WIBAUX COUNTY UST
2ND AVE N PO BOX 86
WIBAUX, MT 59353 WIBAUX

Sys Fac ID: 55-02446

Last Inspected On: 6/11/2013

Operating Permit Renewal Date: 10/15/2016

Contact: Kim Bacon, (406) 796-2446

Owners/Operators: Wibaux County Shop, Owner

(406)-796-2443

ATTN KIM BACON
225 2ND AVE NW
WIBAUX MT 59353-9219

Kim Bacon, UST Class A Operator

Kim Bacon, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	20	6/1/1995	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
2272			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/11/2013	Manual Interstitial Monitor	Deferred	
4,000					
3	20	6/1/1995	Steel Clad	Steel	Flapper Valve (Auto Shutoff)
2273			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/11/2013	Manual Interstitial Monitor	Deferred	
4,000					
4	20	6/1/1995	Steel Clad	Steel	
2274			Double-Walled	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Waste Oil		6/11/2013	Manual Tank Gauging	Deferred	
500					

Facility Summary in WIBAUX County in the City of WIBAUX

Location: WIBAUX COOP OIL CO
203 2ND AVE NW
WIBAUX, MT 59353 WIBAUX

Contact: Donald Lauf, (406) 795-2219

Sys Fac ID: 55-03348
Last Inspected On: 6/11/2013
Operating Permit Renewal Date: 10/23/2016

Owners/Operators: Wibaux Coop Oil Co, Owner (406)-795-2219 PO BOX 178
WIBAUX MT 59353-0178
Donald Lauf, UST Class A Operator
Donald Lauf, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2270			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/11/2013	Continuous Interstitial Monitor	Deferred	
4,000					
2	20	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2271			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		6/11/2013	Continuous Interstitial Monitor	Deferred	
4,000					
8	20	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2267			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/11/2013	Continuous Interstitial Monitor	Deferred	
5,000					
9	20	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2268			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/11/2013	Continuous Interstitial Monitor	Deferred	
4,000					

Facility Summary in WIBAUX County in the City of WIBAUX

Location: WIBAUX COOP OIL CO
203 2ND AVE NW
WIBAUX, MT 59353 WIBAUX

Sys Fac ID: 55-03348

Last Inspected On: 6/11/2013

Operating Permit Renewal Date: 10/23/2016

Contact: Donald Lauf, (406) 795-2219

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	20	6/1/1995	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2269			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		6/11/2013	Manual Interstitial Monitor	Deferred	
4,000					

Facility Summary in WIBAUX County in the City of WIBAUX

Location: AMSLER C STORE
102 2ND AVE N
WIBAUX, MT 59353 WIBAUX

Sys Fac ID: 55-13559

Last Inspected On: 4/17/2014

Operating Permit Renewal Date: 8/22/2017

Contact: Ernst Amsler, (406) 796-2338

Owners/Operators: Amsler C Store, Owner (406)-796-2338 PO BOX 16
WIBAUX MT 59353-0016
Ernest Amsler, UST Class A Operator
Ernest Amsler, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	21	11/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3258			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/17/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
2	22	1/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3259			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		4/17/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
3	22	1/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3260			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/17/2014	Automatic Tank Gauging 0.2	Deferred	
6,000			TLS-350/Gilbarco EMC , Veeder Root		
4	22	1/1/1994	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3261			None	none	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		4/17/2014	Automatic Tank Gauging 0.2	Deferred	
4,000			TLS-350/Gilbarco EMC , Veeder Root		